

WEM Procedure – Developing Limit Advice

WEM Reform Implementation Group (WRIG) 1 October 2020



Contents


- WEM Procedure – Developing Limit Advice
- Overview of Limit Advice
- Developing Thermal Network Limit Advice
- Developing Non-Thermal Network Limit Advice
- Maintaining, Updating, Publishing and Reviews of Limit Advice
- WEM Procedure Consultation



WEM Procedure – Developing Limit Advice

Structure of the WEM Procedure – Developing Limit Advice is as follows:

- Overview
 - Relationship with the WEM Rules
 - Definitions and interpretation
 - Related documents
- Overview of Limit Advice
 - Thermal Network limit advice
 - Non-thermal Network limit advice
- Developing Thermal Network Limit Advice
- Developing Non-Thermal Network Limit Advice
- Maintaining and Updating Limit Advice
- Supporting Information and Data



Overview of Limit Advice

- WEM Procedure: Development of Limit Advice is made in accordance with clauses 1.33.1(b) and 2.27A.11(a) of the WEM rules
- Purpose of the procedure is to document the processes to be followed by Western Power and the matters it must consider in developing and updating limit advice, including the approach taken by Western Power in applying a Limit Margin, Wholesale Market Objectives and good electricity industry practice
- Applies to Western Power as a Network Operator
- Related AEMO WEM Procedures
 - Limit Advice Provision, Constraint Formulation, Congestion information resource, IMS interface, Network modelling data, Power system security

Overview of Limit Advice

What is a network limit?

- Mathematical expression, either a number or equation, defining the power transfer capability across network elements. Western Power must develop two forms of limit advice – thermal network limits and non-thermal network limits
- Note - Procedure expected to be modified to include a third form of limit advice which is related to RCM limit advice.

Thermal network limit

- Network Limits that describe the maximum capacity for electrical throughput of a particular network element due to temperature or related effects
For example: Transmission line EP-ST current rating (summer) = 1063 amps

Non-thermal network limit

- Limits that are not thermal limits - Network limit equations that describe the maximum power that can be transmitted to prevent network voltage or stability problems during network normal or following contingencies
- For example, an equation to maintain network voltage within acceptable limits following a contingency might be of the form:

$$\text{WKT MW Import} \leq \text{constant} + A1.X1 + A2.X2 + A3.X3 + \dots + An.Xn - \text{limit margin}$$

Where A_n is a coefficient and X_n is variable which could include items like active power flow, reactive power flow, output from a generator, number of generators in service, etc.

Developing Thermal Network Limits

- When electricity is transferred along a path, such as between two zone substations, it passes through various equipment such as cables, conductors, switchgear, busbars, transformers, etc.
- All equipment that electricity flows through has a rating which is the amount of power that can safely be transferred through that equipment to prevent equipment damage, or in the case of a transmission line, prevent violation of minimum conductor clearances.
- Equipment ratings are based on various factors such as Australian/International standards, guidelines for the installed equipment and good industry practice.
- The thermal limit is established through identifying the equipment with the lowest rating in the electricity path.
- Thermal limits are provided to AEMO for approximately 256 transmission lines and 408 transformers and applicable busbars.
- Thermal limits for a network element may be different depending on which direction the power flows and for different seasons

408 transformers

Site ID	Equipment ID	ALUMINUM	Equip. Type	1 pu KV	Rating limit	NORM IN
A	A50471 LV	SUM	TRANS	22	AMP	586
A	A50471 LV	WVN	TRANS	22	AMP	1012
A	A50822 LV	SUM	TRANS	22	AMP	754
A	A50822 LV	WVN	TRANS	22	AMP	544
A	A51273 LV	SUM	TRANS	22	AMP	790
A	A51273 LV	WVN	TRANS	22	AMP	595
ALB	ALB51973 LV	WVN	TRANS	22	AMP	900
ALB	ALB50371 LV	SUM	TRANS	22	AMP	789
ALB	ALB50371 LV	WVN	TRANS	22	AMP	927
ALB	ALB51072 LV	SUM	TRANS	22	AMP	999
ALB	ALB51072 LV	WVN	TRANS	22	AMP	1012
ALB	ALB51973 LV	SUM	TRANS	22	AMP	787
AMT	AMT51472 LV	WVN	TRANS	22	AMP	1195
AMT	AMT52473 LV	SUM	TRANS	22	AMP	1012
AMT	AMT52473 LV	WVN	TRANS	22	AMP	1125
AMT	AMT51472 LV	SUM	TRANS	22	AMP	1080
AMT	AMT52473 LV	SUM	TRANS	22	AMP	1021
AMT	AMT52473 LV	WVN	TRANS	22	AMP	1173
APM	APM50473 LV	SUM	TRANS	22	AMP	805
APM	APM50473 LV	WVN	TRANS	22	AMP	544
APM	APM51271 LV	SUM	TRANS	22	AMP	805
APM	APM51271 LV	WVN	TRANS	22	AMP	544
BCH	BCH50471 LV	SUM	TRANS	22	AMP	1000
BCH	BCH50471 LV	WVN	TRANS	22	AMP	1000
BCH	BCH51272 LV	SUM	TRANS	22	AMP	1019
BCH	BCH51272 LV	WVN	TRANS	22	AMP	1128

256 transmission lines




Equipment ID	Site ID	Line Description	# Connections	ALUMINUM	Equip. Type	1 pu KV	Rating limit	NORM IN
A-CPE1	A	A 309 CPE1 CURRENT	2	SUM	LPH	132	AMP	433
A-CPE1	A	A 309 CPE1 CURRENT	2	WVN	LPH	132	AMP	737
A-AD1	A	A 301 H81 CURRENT	2	SUM	LPH	132	AMP	1180
A-AD1	A	A 301 H81 CURRENT	2	WVN	LPH	132	AMP	1180
ALB-CO1	ALB	ALB 510 CO1 CURRENT	2	WVN	LPH	132	AMP	310
ALB-CO1	ALB	ALB 510 CO1 CURRENT	2	WVN	LPH	132	AMP	310
ALB-HB1	ALB	ALB 504 HB1 CURRENT	2	SUM	LPH	132	AMP	250
ALB-HB1	ALB	ALB 504 HB1 CURRENT	2	WVN	LPH	132	AMP	230
ALB-HB1	AMT	AMT 308 HB1 CURRENT	2	WVN	LPH	132	AMP	930
AMT-CB1	AMT	AMT 301 CB1 CURRENT	2	WVN	LPH	132	AMP	1093
AMT-CB1	AMT	AMT 301 CB1 CURRENT	2	WVN	LPH	132	AMP	1093
AMT-CB1	AMT	AMT 308 SB1 CURRENT	2	WVN	LPH	132	AMP	1180
AMT-CB1	AMT	AMT 308 SB1 CURRENT	2	SUM	LPH	132	AMP	1090
AP-CO1	APJ	APJ CO1 CURRENT	2	SUM	LPH	330	AMP	380
AP-CO1	APJ	APJ CO1 CURRENT	2	WVN	LPH	330	AMP	380
APU-AP1	APJ	APJ 510 P1 CURRENT	2	SUM	LPH	132	AMP	422
APU-AP1	APJ	APJ 510 P1 CURRENT	2	WVN	LPH	132	AMP	737
APU-AP1	APJ	APJ 510 P1 CURRENT	2	SUM	TR	132	AMP	802
APU-AP1	APJ	APJ 510 P1 CURRENT	2	WVN	TR	132	AMP	948
APU-AP1	APM	APM 708 H1 CURRENT	2	WVN	LPH	44	AMP	1078
APU-AP1	APM	APM 708 H1 CURRENT	2	SUM	LPH	44	AMP	499
APU-AP1	APM	APM 701 S1 CURRENT	1	SUM	LPH	88	AMP	906
APU-AP1	APM	APM 701 S1 CURRENT	1	WVN	LPH	88	AMP	1078
BCH-H1	BCH	BCH 308 H1 CURRENT	2	SUM	LPH	132	AMP	920
BCH-H1	BCH	BCH 308 H1 CURRENT	2	WVN	LPH	132	AMP	1093
BCH-H1	BCH	BCH 302 HB1 CURRENT	2	SUM	LPH	132	AMP	930
BCH-H1	BCH	BCH 302 HB1 CURRENT	2	WVN	LPH	132	AMP	1093
BCH-H1	BCH	BCH 308 HB1 CURRENT	2	WVN	LPH	132	AMP	924
BCH-H1	BCH	BCH 308 HB1 CURRENT	2	SUM	LPH	132	AMP	924
BCH-H1	BCH	BCH 301 HB1 CURRENT	2	WVN	LPH	132	AMP	934
BCH-H1	BCH	BCH 301 HB1 CURRENT	2	SUM	LPH	132	AMP	981
BCH-H1	BCH	BCH 301 HB1 CURRENT	2	WVN	LPH	132	AMP	448
BCH-H1	BCH	BCH 301 HB1 CURRENT	2	WVN	LPH	132	AMP	418

Developing Non-thermal network limits

- The power transfer into or out of regions of the network may have limits to prevent network voltage or stability problems. Limit equations are developed and provided to AEMO to ensure stability is maintained for various load and generation scenarios and network voltages for system normal and following contingencies.
- Load flow simulation under various conditions (1000s of simulations) to identify power transfer limit to maintain stability
- Develop limit equation to ensure stability maintained at a 95% confidence interval (limit margin) – standard industry practice.
- Limit equation provided to AEMO to formulate constraint equation
- Limit advice is published in the AEMO constraint library

Each equation solves a specific network voltage or stability technical requirement – such as:

- Post contingency voltage > 0.9pu
- Post contingency voltage < 1.1pu
- Post contingency voltage step change < +6%
- Post contingency voltage step change > -10%
- Transient rotor angle criterion
- Oscillatory rotor angle stability
- Short term voltage stability
- Temporary overvoltage criterion
- Long term voltage criterion (QV analysis)



Maintaining, Updating, Publishing and Reviews of Limit Advice

- Western Power must use its reasonable endeavours to ensure that all necessary limit advice is complete, current and accurate at the time it is provided to AEMO and updated as soon as practicable where it identifies significant changes that may affect any limit advice
 - Types of changes that could impact include new generators, new loads, changes to generator models, network augmentations, revised forecasts, revised generator performance, decommissioned plant, modified network protection schemes
- Western Power must advise AEMO if limit advice is inaccurate or incomplete
- Publication - Limit Advice, including Limit Equations and Limit Advice Inputs are provided to AEMO which are then published in the Constraints Library
- Western Power is required to provide AEMO or ERA in a reasonable timeframe information required for their functions or reviews.
- The ERA reviews the effectiveness of Limit Advice provided by Western Power including the appropriateness of any Limit Margins and the appropriateness of the Market Procedure

WEM Procedure Consultation

- The WEM Procedure Limit Advice Development will be circulated shortly
- Please provide feedback or any direct any queries to Western Power
 - RegulatoryReforms@westernpower.com.au
 - Attention – Mark McKinnon (Market & Operations Stream Lead)





Perth office

363 Wellington Street
Perth, WA 6000

westernpower.com.au

