

Addendum to “Facility Dispatch - Curtailable/Dispatchable Loads  
MAC Presentation May 11”

The following example is provided to demonstrate the issue in regard to the current  
Market Rules

Example 1

IPP Liquid Facility Bid = \$450/MWh  
Curtailable Load Bid (Non-Liquid) = \$400/MWh

Dispatch Merit Order is

1. Curtailable Load (Non-liquid)= \$400/MWh
2. Verve Liquid
3. IPP Liquid = \$450/MWh

(This is economic as the lower cost bid is dispatched before the higher cost bid)

Example 2

IPP Liquid Facility Bid = \$450/MWh  
Curtailable Load Bid (Non-Liquid) = \$500/MWh

Dispatch Merit Order is

1. Curtailable Load (Non-liquid)= \$500/MWh
2. Verve Liquid
3. IPP Liquid = \$450/MWh

(This is not economic as it forces the higher cost bid to be dispatched before the lower  
cost bid)