

10 December 2025

Ms Dora Guzeleva
Director, Wholesale Markets
Energy Policy WA
Lodged by email to energymarkets@deed.wa.gov.au

Dear Ms Guzeleva

Addendum to the Essential System Services Framework Review - Consultation Paper

Change Energy appreciates the opportunity to comment on the Addendum to the Essential System Services Framework Review -Consultation Paper.

We fully support increasing the Rate of Change of Frequency (RoCoF) Safe Limit from 0.25 Hz per 0.5 seconds to 0.75 Hz per second to reduce the need for AEMO interventions.

If you have any questions or would like to arrange a meeting to discuss any aspect of this submission, please contact me on 0401 903 210 or at Geoff.Gaston@changeenergy.com.au.

Yours Sincerely,

Geoff Gaston
CEO